

Report Transmission Cover Page

Bill To: City of Parksville 1116 Herring Gull Way Parksville, BC, Canada V9P 1R2	Project ID: Project Name: Project Location: LSD: P.O.: 3960 Proj. Acct. code:	Lot ID: 1424213 Control Number: Date Received: May 20, 2020 Date Reported: May 25, 2020 Report Number: 2516393
Attn: Accounts Payable Sampled By: Barb Silenieks Company: City of Parksville		

Contact	Company	Address
Accounts Payable	City of Parksville	1116 Herring Gull Way Parksville, BC V9P 1R2 Phone: (250) 951-2489 Fax: Email: ap@parksville.ca
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Single Report	PDF	Invoice
Barbara Silenieks	City of Parksville	1116 Herring Gull Way Parksville, BC V9P 1R2 Phone: (250) 951-2489 Fax: Email: bsilenieks@parksville.ca
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Single Report	PDF	COA
Email - Single Report	PDF	COC / Test Report

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report

Bill To: City of Parksville 1116 Herring Gull Way Parksville, BC, Canada V9P 1R2	Project ID: Project Name: Project Location: LSD: P.O.: 3960 Proj. Acct. code:	Lot ID: 1424213 Control Number: Date Received: May 20, 2020 Date Reported: May 25, 2020 Report Number: 2516393
Attn: Accounts Payable Sampled By: Barb Silenieks Company: City of Parksville		

	Reference Number	1424213-1	1424213-2	1424213-3	
	Sample Date	May 19, 2020	May 19, 2020	May 19, 2020	
	Sample Time	09:30	09:30	10:15	
	Sample Location				
	Sample Description	Community Park	Temple St	Ermineskin	
	Matrix	Water	Water	Water	
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Trihalomethanes Screen - Water					
Chloroform	mg/L	0.038	0.023	0.021	0.001
Bromodichloromethane	mg/L	0.004	0.005	0.003	0.001
Dibromochloromethane	mg/L	<0.001	0.002	0.002	0.001
Bromoform	mg/L	<0.001	<0.001	<0.001	0.001
Total Trihalomethanes	mg/L	0.042	0.030	0.026	0.001
Trihalomethanes - Surrogate Recovery					
Dibromofluoromethane	EPA Surrogate %	105	96	100	50-140
Toluene-d8	EPA Surrogate %	103	97	97	50-140
Bromofluorobenzene	EPA Surrogate %	114	114	113	50-140


Analytical Report

Bill To: City of Parksville 1116 Herring Gull Way Parksville, BC, Canada V9P 1R2	Project ID: Project Name: Project Location: LSD: P.O.: 3960 Proj. Acct. code:	Lot ID: 1424213 Control Number: Date Received: May 20, 2020 Date Reported: May 25, 2020 Report Number: 2516393
Attn: Accounts Payable Sampled By: Barb Silenieks Company: City of Parksville		

Reference Number 1424213-4
Sample Date May 19, 2020
Sample Time 10:45
Sample Location
Sample Description Public Works Yard

Matrix Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Trihalomethanes Screen - Water					
Chloroform	mg/L	0.039			0.001
Bromodichloromethane	mg/L	0.003			0.001
Dibromochloromethane	mg/L	<0.001			0.001
Bromoform	mg/L	<0.001			0.001
Total Trihalomethanes	mg/L	0.042			0.001
Trihalomethanes - Surrogate Recovery					
Dibromofluoromethane	EPA Surrogate	%	98		50-140
Toluene-d8	EPA Surrogate	%	95		50-140
Bromofluorobenzene	EPA Surrogate	%	110		50-140

Approved by: 
 Matthew Norman, BSc, PChem
 Operations Chemist

Methodology and Notes

Bill To: City of Parksville 1116 Herring Gull Way Parksville, BC, Canada V9P 1R2	Project ID: Project Name: Project Location: LSD: P.O.: 3960 Proj. Acct. code:	Lot ID: 1424213 Control Number: Date Received: May 20, 2020 Date Reported: May 25, 2020 Report Number: 2516393
Attn: Accounts Payable Sampled By: Barb Silenieks Company: City of Parksville		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
THM - Water	US EPA	* Volatile Organic Compounds by GCMS / Purge and Trap for Aqueous Samples, 8260B/5030B <i>* Reference Method Modified</i>	May 25, 2020	Element Calgary

References

US EPA	US Environmental Protection Agency Test Methods
--------	---

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.