



**ORDER**

**SECTION 93 OF THE *WATER SUSTAINABILITY ACT***

**WHEREAS** The Regional District of Nanaimo, City of Parksville and Town of Qualicum Beach, are the holders of Conditional Water Licence (CWL) C134068;

**WHEREAS** CWL C134068 (October 26, 2017) authorizes the storage of 9,000,000 cubic metres per year in Arrowsmith Lake and the diversion and use of 7,000,000 cubic metres per year from Englishman River for waterworks purpose on all the lands within the boundaries of the Regional District of Nanaimo, City of Parksville, and Town of Qualicum Beach.

**WHEREAS** Clause (l) of the licence states: "The licensee shall release adequate water from storage in Arrowsmith Lake during the period of June 1 to October 31 to fully support the diversion of water from the Englishman River for the waterworks purpose";

**WHEREAS** Clause (m) of the licence states: "The diversion of water authorized under this licence may be regulated at any time by an order in writing from the Water Manager under the *Water Sustainability Act* in order to maintain a minimum flow in the stream";

**AND WHEREAS** on January 2, 2008, an Order under Section 18 of the *Water Act* set out the Provisional Operation Rule for Arrowsmith Lake Reservoir;

Clause 2 of the Order states: "The Arrowsmith Lake Reservoir shall be maintained at the full supply by July 1 of each year"; and

Clause 3 of the Order states: "Between the period of June 1 and October 31 in any year, the flow releases shall be made from the Arrowsmith Lake Reservoir if the Englishman River flow is below 1.6 m<sup>3</sup>/sec, a flow release shall be made to maintain the flow in the Englishman River above 1.6 m<sup>3</sup>/sec at the Englishman River near Parksville (08HB002) hydrometric gauge. (Note – 1.6 m<sup>3</sup>/sec is a quantity greater than instream fish flow maintenance plus future maximum monthly water withdrawal demand)";

**AND WHEREAS** on April 21, 2026, an application was made via email from the City of Parksville to the Ministry of Water, Land and Resource Stewardship (WLRs) to authorize a reduction of the required flow of 1.6 m<sup>3</sup>/sec at the Englishman River near Parksville Water Survey of Canada hydrometric gauge (08HB002). This reduction is necessitated by the current year's water scarcity conditions and reduced supply of stored water in the Arrowsmith Reservoir;

**AND WHEREAS** a flow reduction less than 1.6 m<sup>3</sup>/sec but not less than 1.0 m<sup>3</sup>/sec at 08HB002 would ensure the licensees could maintain a minimum flow of 1.0 m<sup>3</sup>/sec at 08HB002 for the remainder of the flow release period;

**AND WHEREAS** the Englishman River is designated as a Sensitive Stream under the *Water Sustainability Act* and anadromous salmonid species spawn in the Englishman River;

**AND WHEREAS** the licensees will maximize the release of stored water above the low-level outlet of the dam to achieve a steady flow rate greater than 1.0 m<sup>3</sup>/sec at 08HB002 with the intent to gradually ramp down to 1.0 m<sup>3</sup>/sec only if necessary to preserve that minimum flow through October 31, 2026;

**AND WHEREAS** the licensees are implementing watering restrictions as per their bylaws when water from Englishman River is being diverted and used for their water supply;

**AND WHEREAS** the licensees have agreed to provide weekly updates to WLRS, including notification of the intent and rationale to ramp down or ramp up flow releases to a value above or at 1.0 m<sup>3</sup>/s;

**THEREFORE, Under Section 93(1)(c) of the *Water Sustainability Act*, I, Cali Melnechenko, Water Manager, HEREBY ORDER the holders of Conditional Water Licence C134068 the leave to maintain a minimum targeted flow of 1.0 cubic metres per second at the Englishman River near Parksville (08HB002) hydrometric gauge for the period June 1, 2026 to October 31, 2026, or until further order of the Water Manager.**

Dated at Nanaimo, British Columbia, this May 28, 2026.



**Cali Melnechenko**  
**Water Manager**, under the  
*Water Sustainability Act*