

Report Transmission Cover Page

Bill To: City of Parksville 1116 Herring Gull Way Parksville, BC, Canada V9P 1R2	Project ID: Project Name: THM Project Location: Various LSD: P.O.:	Lot ID: 1592356 Control Number: Date Received: Aug 16, 2022 Date Reported: Aug 21, 2022 Report Number: 2777860
Attn: Accounts Payable Sampled By: Barb Silenieks Company: City of Parksville	Proj. Acct. code:	

Contact	Company	Address	
Accounts Payable	City of Parksville	1116 Herring Gull Way Parksville, BC V9P 1R2 Phone: (250) 951-2489 Fax: Email: ap@parksville.ca	
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>	
Email - Single Deliverable	PDF	Invoice	
Barbara Silenieks	City of Parksville	1116 Herring Gull Way Parksville, BC V9P 1R2 Phone: (250) 951-2489 Fax: Email: bsilenieks@parksville.ca	
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>	
Email - Single Deliverable	PDF	COA	
Email - Single Deliverable	PDF	COC / Test Report	
Email - Single Deliverable	Standard Crosstab Without Tabs	Test Report	

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report

Bill To: City of Parksville 1116 Herring Gull Way Parksville, BC, Canada V9P 1R2	Project ID: Project Name: THM Project Location: Various LSD: P.O.:	Lot ID: 1592356 Control Number: Date Received: Aug 16, 2022 Date Reported: Aug 21, 2022 Report Number: 2777860
Attn: Accounts Payable Sampled By: Barb Silenieks Company: City of Parksville	Proj. Acct. code:	


	Reference Number	1592356-1	1592356-2	1592356-3	
	Sample Date	Aug 15, 2022	Aug 15, 2022	Aug 15, 2022	
	Sample Time	09:00	09:10	09:20	
	Sample Location				
	Sample Description	Community Park / 17.1 °C	Temple St / 17.1 °C	Ermineskin / 17.1 °C	
	Matrix	Water	Water	Water	
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Trihalomethanes Screen - Water					
Chloroform	mg/L	0.024	0.026	0.027	0.001
Bromodichloromethane	mg/L	0.007	0.009	0.007	0.001
Dibromochloromethane	mg/L	0.003	0.002	0.002	0.001
Bromoform	mg/L	<0.001	<0.001	<0.001	0.001
Total Trihalomethanes	mg/L	0.034	0.037	0.036	0.001
Trihalomethanes - Surrogate Recovery					
Dibromofluoromethane	EPA Surrogate %	112	112	111	50-140
Toluene-d8	EPA Surrogate %	98	98	100	50-140
Bromofluorobenzene	EPA Surrogate %	105	96	99	50-140

Analytical Report

Bill To: City of Parksville 1116 Herring Gull Way Parksville, BC, Canada V9P 1R2	Project ID: Project Name: THM Project Location: Various LSD: P.O.:	Lot ID: 1592356 Control Number: Date Received: Aug 16, 2022 Date Reported: Aug 21, 2022 Report Number: 2777860
Attn: Accounts Payable Sampled By: Barb Silenieks Company: City of Parksville	Proj. Acct. code:	

Reference Number	1592356-4	1592356-5
Sample Date	Aug 15, 2022	Aug 15, 2022
Sample Time	09:45	09:50
Sample Location		
Sample Description	Public Works Yard (PWY) / 17.1 °C	Water Treatment Plant (WTP) / 17.1 °C
Matrix	Water	Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Trihalomethanes Screen - Water					
Chloroform	mg/L	0.066	0.019		0.001
Bromodichloromethane	mg/L	0.011	0.004		0.001
Dibromochloromethane	mg/L	0.001	<0.001		0.001
Bromoform	mg/L	<0.001	<0.001		0.001
Total Trihalomethanes	mg/L	0.078	0.023		0.001
Trihalomethanes - Surrogate Recovery					
Dibromofluoromethane	EPA Surrogate %	117	116		50-140
Toluene-d8	EPA Surrogate %	97	98		50-140
Bromofluorobenzene	EPA Surrogate %	97	100		50-140

Approved by: 
 Mike Yohemas, BSc
 General Manager

Methodology and Notes

Bill To: City of Parksville 1116 Herring Gull Way Parksville, BC, Canada V9P 1R2	Project ID: Project Name: THM Project Location: Various LSD: P.O.:	Lot ID: 1592356 Control Number: Date Received: Aug 16, 2022 Date Reported: Aug 21, 2022 Report Number: 2777860
Attn: Accounts Payable Sampled By: Barb Silenieks Company: City of Parksville	Proj. Acct. code:	

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
THM - Water	US EPA	* Volatile Organic Compounds by GCMS / Purge and Trap for Aqueous Samples, 8260B/5030B <i>* Reference Method Modified</i>	Aug 17, 2022	Element Calgary

References

US EPA	US Environmental Protection Agency Test Methods
--------	---

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.