





## Update #21 November 2024

### November: ERWS Consumption Percentage



■ Parkville ■ RDN

### November: Production Source



■ Wells ■ ERWS

### November: Total Production (Wells & ERWS)

142,935 m<sup>3</sup>


## Englishman River Water Service

- Heavy rains and windstorms lead to loss in production due to lack of pre-treatment options. The plant was shut down during storm events as a precautionary measure to reduce the negative impacts on equipment and membrane health.
- Temporary administrative assistance in place to upload assets into FIX program.
- Daily total dissolved solids samples have been added to the sampling program.

## Arrowsmith Water Service

- Staff inspected the dam one last time before the snow arrived.

## Mount Cokely Weather Station 3B02A



## Dam Lake Level

